

SGS

Validation of Certificate

The Validation of Certificate is for the Cleanroom floor scrubber machine I-MOP XL by the Future Cleaning Technologies B.V.

Certification Number: VoC-SHST2411000503CR
Certification issue date: 2023-10-23
Valid period: 2026-10-23
Reference Test Report: SHSUTA2309000359CR
Applicant: Future Cleaning Technologies B.V.
Address: Hoppenkuil 27A 5626 DD Eindhoven NL
Type of product: I-MOP XL
Trademark:



Within the scope of ISO 14644-14:2016 Cleanrooms and associated controlled environments — Part 14: Assessment of suitability for use of equipment by airborne particle concentration. Accordingly, the particle emission tests under simulated run test for sweeping and vacuuming mode by SGS.

This product – Cleanroom floor scrubber machine I-MOP XL overall result are conforming the requirements for particle emission cleanroom.

Dry-brush model (brush the floor and vacuum without spray water mode): I-MOP XL has cleanroom suitability for use within a cleanroom of **ISO Class 5 (0.5 µm)**.

Wet-brush model (brush the floor and vacuum with spray water mode): I-MOP XL has cleanroom suitability for use within a cleanroom of **ISO Class 6 (0.5 µm)**.

